
To: Emilio Murga
Cc: Emilio De Murga
Subject: RE: Addendum No. 4, Attendance List and answers to questions, Second site visit, March 31, 2022, So. Gate Police Dept. HVAC Installation Project.

From: Emilio Murga
Sent: Tuesday, April 5, 2022 10:19 AM
To: William Rojo <rojo@wdrcontracting.com>; bbonacic@allison1.net; gramirez@maierint.com; thierry@ranent.com; estimating@acprosinc.com; kevin@edaincorporated.com; mfeyka@fmthomas.com; ross.s@pacwestac.com; idelarosa@maierint.com
Cc: Devon Charnley <dcharnley@csceng.com>; Emilio De Murga <edemurga@willdan.com>; Alan Galvan <agalvan@sogate.org>
Subject: Addendum No. 4, Attendance List and answers to questions, Second site visit, March 31, 2022, So. Gate Police Dept. HVAC Installation Project.

Prospective Bidders,

Please see answer to question below by William Rojo, WDR Contracting, regarding ceiling tiles:

All ceiling tiles in the areas with open ceilings (i.e. no hard lid above) are to be discarded as ACM. T-bars can be cleaned. Ceiling tiles in the areas with a hard lid above should be inspected for acoustic/ACM debris and if found, discarded as ACM. Ceiling tiles in those areas with a hard lid and no ACM debris can remain.

Please contact me if you have questions.

Thank you for your interest in the project.

Emilio M. Murga
(562) 505-1001

From: William Rojo <rojo@wdrcontracting.com>
Sent: Tuesday, April 5, 2022 9:48 AM
To: Emilio Murga <emurga@sogate.org>
Cc: bbonacic@allison1.net; mfeyka@fmthomas.com; gramirez@maierint.com; idelarosa@maierint.com; estimating@acprosinc.com; ross.s@pacwestac.com; thierry@ranent.com; kevin@edaincorporated.com; Devon Charnley <dcharnley@csceng.com>; Emilio De Murga <edemurga@willdan.com>; Alan Galvan <agalvan@sogate.org>
Subject: Re: Addendum No. 4, Attendance List and answers to questions, Second site visit, March 31, 2022, So. Gate Police Dept. HVAC Installation Project.

Hello,

CSC's answer to question number 4. Ceiling tiles says that the ceilings may be cleaned but they do not recommend

- Can you please clarify if we are to dispose of the ceiling tiles as ACM or are we cleaning them?

Thank you

William Rojo | Ph. 626.975.1077

www.wdrcontracting.com

CSLB # [946226](#) | DOSH # [1015](#)

Asbestos Abatement • Demolition Services

On Apr 5, 2022, at 9:12 AM, Emilio Murga <emurga@sogate.org> wrote:

Prospective Bidders,

Attached please see the following:

1. Attendance list to second site visit, held March 31, 2022, SGPD HVAC Installation Project.
2. Answers to questions raised at site visit, held March 31, 2022, SGPD HVAC Installation Project.
3. Addendum No. 4, stating that the Non-Collusion Affidavit must be submitted with the bid.

For project information please visit:

<http://www.ebidboard.com/public/projects/index.asp?mbrguid={BF2C74EF-A2E4-4DE1-838F-6B35DAA0E099}>

<https://www.cityofsouthgate.org/Business-Development/Bids-RFPs/SGPD-HVAC-Installation-Project>

Bid opening: Tuesday, April 12, 2022, 11:00 a.m.

Please contact me if you have questions.

Thank you for your interest in the project,

Emilio M. Murga
Project Manager
Engineering Division
City of South Gate
(562) 505-1001